

CITY OF SAUSALITO

Addendum No. 1

Notice Issued March 17, 2014

For: Sausalito Fishing Pier Repair Project

NOTICE TO ALL PLAN HOLDERS SUBMITTING BIDS FOR THIS WORK:

You are hereby notified of the following information, changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. The Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain, UNCHANGED.

This Addendum is hereby made a part of the Contract Documents to the same extent as though it was originally included therein.

Clarification:

Sheet D1.1 Demolition Plan

Piles marked BAD are to remain in place and not be removed or demolished.

End of Clarification

Drawing Revision:

Sheet S0.0 Structural Notes is modified with the following additions to 06000 WOOD:

7. Cedar decking shall be Port Orford or Alaskan Yellow Cedar, No. 1 & Better, Rough Face, Surfaced Backside to 2 ¾" Thick, Free of Heart, Free of Wane, Free of Sap
8. Glulam beams shall be balanced laid up Alaskan Yellow or Port Orford Cedar in the specified finished dimensions."

End of Revision

Comments:

- Responses to Request for Information

END OF ADDENDUM NO. 1

ACKNOWLEDGED

Bidder's Signature

A signed copy of this addendum is to be submitted as a part of the bid package for the subject project. Failure to do so may subject the Bidder to Disqualification.