

## **Checklist for Backup Generator Permitting for Wireless Sites (AB 2421)**

Signature

		PROJECT ADDRESS:		_	
Initials		<ol> <li>Projects eligible for expedited wireless backup generator permitting process are ones that have YES checked for each criteria below</li> <li>If any items are checked NO, revise design to fit within Checklist, otherwise permit application may go through the standard process.</li> </ol>			
miciais	GENERAL REQUIREMENTS				
	В. С.	Generator must be under 50 horsepower  Generator must have 300 gallons or less of associated fuel storage capacity in double-walled tanks  In total generator and storage tank may not exceed 250 cubic feet in volume  All generators must be mounted on a concrete pad located no more than 100 feet from the	□ Y □ Y	□ N □ N □ N	
Initials	E. F.	tower  Generator must meet minimum air quality standards, building and fire safety codes The applicant must receive all necessary permits (building, air, etc.)  ISE REQUIREMENTS	<ul><li> Y</li><li> Y</li><li> Y</li><li> Y</li></ul>	<ul><li>N</li><li>N</li><li>N</li><li>N</li></ul>	
Initials	A.	The generator is consistent with regulations for emergency generators under SMC 12.16.135	□ Y	□N	
	SUBMITTAL REQUIREMENTS				
	В. С.	Building Permit application form Checklist for backup generators for wireless sites Structural calculations Generator Plan Set i. Cover sheet, technical notes, site plan, elevations, details of construction, specifications of generator, and electrical plans	<ul><li> Y</li><li> Y</li><li> Y</li><li> Y</li><li> Y</li><li> Y</li></ul>	<ul><li>N</li><li>N</li><li>N</li><li>N</li><li>N</li><li>N</li></ul>	
	CERTIFICATION				
	I, the applicant, do hereby, under penalty of perjury, swear that the information contained in on this checklist is true and correct to the best of my knowledge				

Date

Name of Applicant