

CITY OF SAUSALITO

Sausalito, CA 949654

Addendum No. 2

Notice Issued May 27, 2010

For

Priority 1 Sewer Replacement, Project 1B, Spinnaker/Humboldt Street Sewer & Anchor Street Pump Station Rehabilitation

NOTICE TO ALL PLAN HOLDERS SUBMITTING BIDS FOR THIS WORK:

You are hereby notified of the following information, changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. The Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain, UNCHANGED.

This Addendum is hereby made a part of the Contract Documents to the same extent as though it were originally included therein.

On Sheet C01, ADD Note 6 as follows:

“6. Coordinate directly with PG&E regarding the gas main on Humboldt Street, including but not limited to request for PG&E filed observation and PG&E control of gas flow.”

On Sheet C02, Lift Station Note 5, ADD the following:

“Coordinate lift station control panel requirements with PG&E new service.”

On Sheet C03, Plan Notes (top of sheet), ADD Note 7 as follows:

“7. City will consider trenchless methods for constructing the new sanitary sewer upstream of Station 20+63. Contractor shall demonstrate ability of trenchless method to maintain accurate line and grade.”

A digital copy of a soils investigation report prepared by DCM/GeoEngineers Engineering, dated September 2009, and called out on in Section 2300, 1.02 has been put up on the City of Sausalito Website as of May 27, 2010

END OF ADDENDUM NO. 2

ACKNOWLEDGED:

Bidder's Signature

A signed copy of this addendum is to be submitted as a part of the bid package for the subject project. Failure to do so may subject the Bidder to disqualification.